




NOTES:

ALL ELECTRICAL WORK SHALL BE IN ACCORDANCE WITH THE CALIFORNIA ELECTRICAL CODE. CALIFORNIA ELECTRICAL CODE.

CONTROLLER, ENCLOSURE, AND ALL OF THE REQUIRED COMPONENTS SHALL BE PART OF A PRE-ASSEMBLED SATELLITE ASSEMBLY.

PROVIDE A SEPARATE 5/8 INCH DIA x 8 FOOT COPPER GROUND ROD, WIRE, AND CLAMP INSIDE CABINET FOR ELECTRICAL SERVICE PURSUANT TO THE CALIFORNIA ELECTRICAL CODE.

©Copyright 2000 Global Digi-tech, LLC - The pictorial and graphic expressions displayed with this work are copyrighted under the laws of the United States and shall be used only on projects under the jurisdiction of the agency listed below.

REVISIONS	CITY OF IRVINE	STANDARD PLAN NO.
	SATELLITE CONTROLLER, EXTERIOR INSTALLATION	515
	 Approved by: Mark L. Carroll R.C.E. 31515 City Engineer	Sheet 1 of 1
	Date: 6-22-09	