

## NOTE:

- 1. TOP OF ROOT CONTROL BARRIER MUST BE AT GRADE.
- POSITION ROOT CONTROL BARRIER ADJACENT TO STRUCTURE.
- RAISED ROOT DEFLECTORS MUST BE FACING PLANTED AREA. 3.
- PROVIDE A MIN. OF 12 FEET OF ROOT BARRIER EACH SIDE OF TREE TRUNK. 4.
- 5.
- ROOT BARRIER SHALL EXTEND A MIN. OF 18 INCHES BELOW GRADE ON WALK SIDE. ROOT BARRIER SHALL EXTEND A MIN. OF 24 INCHES BELOW GRADE ON CURB SIDE.
- TREE PLANTING AND STAKING SHALL BE PERFORMED IN ACCORDANCE WITH STANDARD PLAN NOS. 604 THROUGH 607.

© Copyright 2000 Global Digi-tech, LLC - The pictorial and graphic expressions displayed with this work are copyrighted under the laws of the United States and shall be used only on projects under the jurisdiction of the agency listed below.

REVISIONS	CITY OF IRVINE	STANDARD PLAN NO.
	ROOT BARRIER	608
	Approved by: Mark L. Carroll R.C.E. 31515 City Engineer Date 6-22-09	Sheet 1 of 1